



Metropolitan Water Reclamation District of Greater Chicago

100 East Erie Street
Chicago, IL 60611

Legislation Details (With Text)

File #: 10-0009 **Version:** 1

Type: Report **Status:** Filed

File created: 1/12/2010 **In control:** Maintenance & Operations Committee

On agenda: 1/21/2010 **Final action:** 1/21/2010

Title: Report on ComEd's Energy Cooperative Programs at MWRDGC Facilities

Sponsors:

Indexes:

Code sections:

Attachments: 1. Table summary for Rider CLR, 1-7-10 Brd. Mtg..rtf

Date	Ver.	Action By	Action	Result
1/21/2010	1	Committee of the Whole	Recommended	Pass
1/21/2010	1	Board of Commissioners	Published and Filed	Pass

TRANSMITTAL LETTER FOR BOARD MEETING OF JANUARY 21, 2010

COMMITTEE ON MAINTENANCE AND OPERATIONS

Mr. Richard Lanyon, Executive Director

Report on ComEd's Energy Cooperative Programs at MWRDGC Facilities

Dear Sir:

During 2009, the District continued participation in the Energy Cooperative Programs, Rider CLR - Curtailable Load Cooperative, and Rider VRS - Voluntary Resource Sharing, offered by ComEd, a unit of Exelon Corporation. Through voluntary curtailments by the participants, ComEd is able to defer the need for additional generating capacity necessary to meet the very short-lived peak demands expected during the summer months. In return, the participants receive compensation based on the average of their load reductions.

Although ComEd did not invoke a load curtailment in 2009, the District received compensation in the amount of \$426,548.27 for our participation. The District has realized a cumulative savings of \$4.1 million dollars since participation began in 1997.

The Stickney, North Side, Calumet, Egan, and Kirie Water Reclamation Plants, and the Mainstream Pumping Station participated in these programs. In prior years, the load curtailments were achieved by cutting back on aeration and pumping for relatively short durations, delaying process operations and other non-essential loads, and switching some loads to emergency generators, while fully complying with NPDES permit requirements.

The District's participation since 1997 is summarized in the attachment.

The Maintenance and Operations staff at the facilities mentioned have worked diligently to make this program a success by analyzing and applying Rider CLR to the appropriate District facilities and implementing load reductions on the curtailment days without compromising plant performance and treatment quality.

Respectfully Submitted, Osoth Jamjun, Director of Maintenance and Operations, OJ:MPS:SOC:MAG

Attachment