






EXHIBIT 1
PROPOSED FLOODING
CONDITIONS
ALTERNATIVE 2
VILLAGE OF GLENCOE


 Watershed


 Subwatersheds


 Parcels


 Buildings (Not Impacted)

 3 Parcels (Impacted)


 2 Buildings (Impacted)


 Railroad


 Existing Storm Sewer


 Proposed Storm Sewer


Flooding Conditions

 2-Year Storm

 10-Year Storm

 25-Year Storm

 50-Year Storm

 100-Year Storm

CRITICAL AREAS	DESIGN STORM	ELEVATION	DEPTH
1. GREEN BAY RD and LINDEN AVE	10-YR, 2-HR	657.15	NO PONDING
	100-YR, 2-HR	660.36	NO PONDING
2. EUCLID AVE and WOODLAWN AVE	10-YR, 2-HR	659.68	NO PONDING
	100-YR, 2-HR	661.81	NO PONDING
3. GREEN BAY RD and JACKSON AVE	10-YR, 2-HR	656.34	NO PONDING
	100-YR, 2-HR	660.04	0.54-FT

